

**JAMISON SOUND DOOR SPECIFICATIONS**  
**HORIZONTAL SLIDING SOUND REDUCTION DOOR - STC 55**  
**POWERED OPERATION**

**PART 1 - GENERAL**

1.1 **APPLICABLE PUBLICATIONS:** The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by the basic designation only.

1.1.1 **FEDERAL SPECIFICATION:** QQ-Z-325 Plating, Zinc (Electrodeposited), Type I, Class 3.

1.1.2 American Society for Testing and Materials (ASTM), 1916 Race Street, Philadelphia, PA 19103

A36 Structural Steel

A325 High Strength Carbon Steel Bolts for Structural Joints, Including Suitable Nuts and Plain Hardened Washers

E90-85 Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

E413 Determination of Sound Transmission Class

1.2 **SUBMITTALS:**

1.2.1 **APPROVAL DRAWINGS:** It is intended that approval drawings will not be required for these items and that the manufacturers details, along with this specification, will provide all needed information. If it is determined that more specific details are required, six copies of an approval drawing can be furnished upon request.

1.2.2 **SHOP DRAWINGS:** Shop drawings may be specified when required. If provided, drawings shall be submitted prior to delivery of materials to the jobsite. Drawings shall include detail assembly drawings showing the complete installation, a listing of all materials, surface finishes, fabricating assembly and installation tolerances.

1.3 **GENERAL REQUIREMENTS**

1.3.1 **GENERAL:** Sound reduction doors shall be provided complete with frames, gaskets, fasteners, anchors, hardware, sealing systems, and all other equipment and accessories as indicated, specified and necessary for a complete installation to meet the acoustical performance and operational requirements specified herein.

1.3.2 **QUALIFICATIONS OF MANUFACTURER:** The manufacture of the sound reduction doors shall be performed by a manufacturer who has at least fifteen (15) years of proven successful experience in the design and fabrication of similar acoustical doors. The organization shall be regularly engaged in this type of work and shall have complete facilities, equipment, and technical personnel for the design and fabrication of the complete system.

1.3.3 **PROVISIONS FOR INSTALLATION:** The contractor will employ an organization other than the manufacturer to install the sound reduction doors in the field provided the following requirements are complied with.

- a. The organization shall have trained and skilled mechanics with previous experience in the installation of similar precision fabricated assemblies.
- b. The door manufacturer may have a trained engineer or mechanic at the jobsite supervising the unloading, erection, final adjustments and final check out of the doors, frames, hardware, and accessories if requested by the contractor.

## **PART 2 - PRODUCT**

2.1 GENERAL: Materials and equipment specified hereinafter will establish the minimum requirements for quality and performance.

2.1.1 DOOR PANELS AND FRAMES: Door panels shall be fabricated from cold rolled steel and hot rolled pickled and oiled steel. Steel shall not be less than 16 gauge (.060"). Steel shall be straight and free of twist.

2.1.1.1 Door panels shall have an inner core of non-resonating, fire resistant, inorganic, and acoustically damping material. Face sheets shall be stiffened by steel stiffeners with welds not more than six inches (6") apart.

Door panels shall have internal reinforcing for external hardware to adequately stiffen and provide sufficient thickness for tapping to achieve four (4) full thread engagement of bolts. Doors shall be a minimal four inches (6") thick.

2.1.1.2 Header shall be constructed of structural steel channel, tube, or of steel plate. A carriage track support angle shall be welded to the header. The header shall be securely fastened to the wall with 3/4" diameter grade 5 studs.

2.1.2 BOLTED AND SCREWED CONNECTIONS: Bolts shall conform to ASTM A325 or have a minimum strength of 105,000 psi. Bolt holes shall be drilled or punched and at right angles to member. When assembled, all joint surfaces, including those adjacent to bolt heads, nuts or washers, shall be free of burrs, dirt and other foreign material that would prevent solid seating of the parts.

2.1.2.1 All fasteners shall be finished per QQ-Z-325.

2.1.3 SEALS: Door seals shall be provided as indicated herein to achieve the required sound attenuation. Sides and head shall be sealed with a single seal providing a gasketed overlap of door against frame. These gasket assemblies shall be adjustable to provide the proper compression of the seals.

2.1.4 HARDWARE: Door hardware shall be provided as required to accommodate the design loads and acoustical performance as follows:

- a. Doors shall be carried by two trucks consisting of two trolley wheels each. The trolley wheels shall consist of a flame hardened steel tire, ball bearings, and be lubricated for life. The maximum radial load of the bearings shall exceed the door weight by a factor of six.
- b. Each truck shall be securely fastened to the door panel with an adjustable hanger bolt to raise or lower the door. The hanger bolt shall be 1" minimum diameter and be galvanized.
- c. The door shall be forced inwardly to maintain a gasket seal by stay rollers at the floor line and a set of cam roller devices at the head.
- d. The cam roller devices and a drop sill seal are actuated by an electromechanical linear actuating system. This latching mechanism shall only be actuated when the door is in the closed

position. The actuator motor is 120 VAC, 60 HZ, single phase.

2.1.5 POWER OPERATION: Power operation of the sliding door shall be provided by an electromechanical device consisting of a motor, gear reducer, and chain drive.

- a. The motor shall be rated for 1/2 hp minimum, TEFC, NEMA Class B, 480 VAC, 3 phase, 60 HZ. The motor shall have thermal overload protection.
- b. The gear reducer shall be encased in a cast iron housing and conform to AGMA standards.
- c. The operator shall drive the door at an opening and closing speed not to exceed 12 inches per second.
- d. The power operator shall be electrically connected using 600 VAC connectors. The opening/closing relay shall be operated at 24 VAC. The electrical switchgear are to be mounted in a NEMA I rated enclosure.
- e. One NEMA IV rated push button station to be furnished. Station shall have "Open", "Close" and "Stop" buttons.
- f. An electrical interconnection shall provide a cutout to prevent the door from opening when latched, and from latching when open.

### **PART 3 - EXECUTION**

#### 3.1 INSTALLATION:

3.1.1 GENERAL: The installation shall be carefully performed by skilled mechanics. Special care must be exercised to follow the manufacturers printed instructions including recommended tolerances to achieve required acoustical seal.

3.1.2 Store doors and frames at the building site under cover. Place units well above the ground to prevent rust and damage and to provide room for air circulation. Avoid the use of non-vented plastic or canvas shelters that create humidity chambers.

3.1.3 Install frames plumb, rigid, in true alignment, and fasten them to retain their position and clearance during wall construction. Fill frames in masonry walls with mortar as the wall is laid up.

3.1.4 Install doors plumb and in true alignment. Operate doors and verify that doors open and close smoothly with no binding. Inspect fit of all door seals. Inspect final erection and fit of all assemblies and components.